



Turner Construction Company
2001 N. Lamar, Suite 100
Dallas, TX 75202
Phone: (214) 721-8400
Fax: (214) 721-8493

8/2/11

Mr. Bill Burke
Collin County
4600 Community Ave.
McKinney, TX 75071

RE: **Collin County Courthouse Addition**
Owner Project #R0508003.00
Turner Project #1692600

SUBJ: PCO #135 – Modify FEC's to Fit in Walls.

Dear Mr. Burke:

We have finalized the required quotations for PCO #135 – Modify FEC's to Fit in Walls.

We have reviewed the scope of work and have verified that all extra work items are in compliance with our contract agreement. Attached is a detailed itemization of the extra costs. Total amount of this request is **Three Thousand Five Hundred Thirty Eight dollars (\$3,538)**.

If you have any questions regarding this Change Order Request, please call me at your earliest convenience. This pricing is valid for (5) days, after which, we reserve the right to re-evaluate.

Please review and acknowledge your approval in the space below. Once approval is achieved, we will expect this PCO to be included in a forthcoming Change Order.

Best Regards,

J. Leos

John Leos

Approved by:

Collin County

B. Harris

PGAL

Date

8.5.11

Date

cc: Brad Harris & Sara Hoglund- Collin County
Brian Nicodemus- PGAL
Matt Nail & Kevin Karagias- TCCo

T. King Building Services, Inc.
2532 North Interstate 35E
Lancaster, TX 75134
972.276.0400 phone
972.276.0600 fax

PCO # 135



BUILDING SERVICES

Change Order Request

To	From
Shawn Dickey Turner Phone: 214-721-1921 Fax: 214-721-8494 Pages: 1ea Sent Via: email	Kyle Hege T. King Building Services, Inc. Phone: 972-276-0400 Fax: 972-276-0600 Date: 8/2/11

RE: **Collin County Courthouse Addition – COR #2 Rev1**

Scope of Work:

Spec Sect 105230 Fire Protection Specialties

Cost to revise the following Fire Extinguisher Cabinet models to accommodate field verified wall depths:

- (55) ea SS2409-R3, H-Duo
- (32) ea FS SS2409-R3, H-Duo

Add \$21,390.00

- (55) ea SS2409-R1, H-Duo
- (32) ea FS SS2409-5R, H-Duo

Deduct <\$18,280.00>

TOTAL ADD \$ 3,110.00

FEC-4 REPLACED WITH FEC-3
AND

USE FEC-1 WHERE REQUIRED

Inclusions

- Insurance

Exclusions

- Any work not listed above
- Sales Tax

Thanks,
Kyle Hege

-----Original Message-----

From: Kyle Hege [mailto:khege@tkingbuilding.com]
Sent: Monday, July 25, 2011 2:48 PM
To: Leos, John - (TEXAS); Dickey, Shawn - (TEXAS)
Cc: Karagias, Kevin - (TEXAS); Comis, Walt - (TEXAS)
Subject: Collin County Courts

John,

The returned approved Fire Protection Submittal will not work for the above reference project due to the following reasons:

- A.
Specs and plans are calling for an FEC-1 which requires a wall depth of 5 1/4". Currently on site the wall depth is only 4 1/4". This requires FEC-1 to be changed from Model SS2409-R1 to be Model SS2409-R3
- B.
Specs and plans are calling for a Fire Rated FEC-4 which requires a wall depth of 4 7/8". Currently the on site wall depth ranges from 3 1/4 - 4 1/4". This requires FEC-4 to be changed from Model FS SS2409-5R to be Model FS SS2409-R3.

The attached Change Order Request is for cost associated with changing to FEC models that will work with actual wall depths in the field. The specified models require deeper walls.

Regards,

Kyle Hege
Project Manager
T. King Building Services, Inc.
2532 North Interstate 35E
Lancaster, Texas 75134
972.276.0400 phone
972.276.0600 fax