



COLLIN COUNTY, TEXAS

ADDENDUM No. One (1)

IFB NO. 10042-12

INVITATION FOR BIDS  
FOR  
CONSTRUCTION, FUELING STATION CANOPIES

DATE: January 26, 2012

NOTICE TO ALL PROSPECTIVE BIDDERS:

YOU ARE HEREBY DIRECTED TO MAKE CHANGES TO THE INVITATION FOR BIDS IN ACCORDANCE WITH THE ATTACHED INFORMATION.

Clarifications:

1. For this project the workday will begin at 8:00 am, Saturday work will be possible.
2. The McKinney and Farmersville canopies must be installed and completed in one location prior to beginning the other location. The County will not be able to have both sites closed at the same time. In Farmersville the two canopies scheduled for that location can be installed at the same time. The McKinney location will require one side of the pumps to be open until steel erection begins.
3. As-builts for the McKinney location are not available. As such we will not entertain the option to extend the current columns and set a new canopy. Only price new piers, columns and canopies for both the McKinney and Farmersville locations. Piers must be hand dug for the first three feet. The County has no record of conduit or piping at the proposed pier locations seen during walks.
4. At the time of install the dispensers will need to be protected from any damage due to construction.

Add: Alternate 2 for lightning protection at the current canopy at the McKinney Service Center.

PLEASE NOTE ALL OTHER TERMS, CONDITIONS, SPECIFICATIONS DRAWINGS, ETC. REMAIN UNCHANGED.

SINCERELY,  
FRANKLIN YBARBO  
PURCHASING AGENT