



COLLIN COUNTY

Public Works Department
700 A. Wilmeth Road
McKinney, Texas 75069
www.collincountytx.gov
972-548-3700 (Phone)
972-548-3754 (Fax)

23 February 2012

TO Judge Self and Commissioners' Court
FROM Jon Kleinheksel, Public Works Director *JK*
RE Award of Bid, IFB 12075-12
Replacement of Fuel Tank Dispensers
and Fuel Tank Monitoring Systems

Equipment Services requests your consideration and approval to award this bid to the lowest overall bidder, Evans Pump Company, Inc. at a total cost of \$81,207.21. This vendor included a trade-in offer of \$5,128 for the old tank monitoring equipment being replaced, which we recommend.

This award includes replacement of the all the fuel dispensers at both the Service Center and Farmersville sites. The original equipment at these dispensing locations is antiquated, and we are having difficulty finding replacement parts. (Currently, one of the dispensers at Farmersville is completely out of service). These dispensers were installed when the buildings were erected. We have spent many dollars keeping these dispensers operational over the past few years. Funding for this replacement was approved in the FY12 budget.

Likewise, the replacement of the old tank monitoring systems at all our fuel tank sites (Farmersville, Service Center and Justice Center) was approved in the FY12 budget. The current system is now obsolete and is no longer supported by the manufacturer, making it very difficult to find replacement parts. We have experienced many problems with these systems of late and we are mandated by TCEQ to have an operational leak detection system on all the tanks at all times, even those that are for generators only. The new system offered will consolidate all leak detection monitoring into one central system providing continuous leak detection for all the county tanks (as well as monitoring the fuel lines at the Central Plant/Justice Center that feed the generators). This system will be monitored 24/7 in the Facilities control room as well as at the Service Center during normal work hours.

A breakdown of costs associated with each system is attached.

If you need additional information, please contact me and I will respond accordingly.