



**COLLIN COUNTY**

Construction and Planning  
4600 Community Ave.  
McKinney, Texas 75071

To: Bill Bilyeu

From: Bill Burke

Date: 12-11-12

Subject: Change Order for Dal-Ec. Construction – Myers Park Electric Upgrade

PCO #1 – Owner requested separation of lighting from I.T. circuit. \$228.14

PCO #2 – Engineer requested shunt trip breakers to be added to service the fire suppression system in the concession kitchen. The existing shunt trips could not be seen behind the face of the panel until the cover was removed. \$1,888.34

This change order totals - \$2,007.32 reduced from \$2,116.48 due to \$109.16 allowance.

Total Change Orders for the Project are \$2,007.32 or 1.1% of contract.

YBS ok 12/11/12



# Dal-Ec. Construction, Ltd.

December 10, 2012

Myers Park & Event Center – Electrical Upgrade

Change Order Request:

Change 3 60-amp 2-pole breakers serving cooling equipment under vent hood in kitchen area to shunt trip breakers.

Material =	\$1,566.67
Labor =	<u>150.00</u>
Subtotal =	\$1,716.67
H & P - 10% =	<u>171.67</u>
TOTAL =	\$1,888.34

  
\_\_\_\_\_  
Don Wilbanks, President

408-B Interchange Street  
McKinney, TX 75071

Phone: 214-544-2121 Fax: 972-542-7097

TDLR License No. 18171

Regulated by The Texas Department of Licensing and Regulation  
P. O. Box 12157, Austin, Texas 78711, 1-800-803-9202, 512-463-6599  
website: [www.license.state.tx.us/complaints](http://www.license.state.tx.us/complaints)



# Dal-Ec. Construction, Ltd.

December 3, 2012

Myers Park & Event Center – Electrical Upgrade

Change Order Request:

Pull new circuit from Panel F.A. to Existing outside lights on west side of building that were tapped off IDEN Mini-circuit. Use spare breaker circuit FA-13.

Material –	\$57.40
Labor =	150.00
Subtotal =	<u>\$207.40</u>
H & P - 10% =	<u>\$20.74</u>
TOTAL =	\$228.14

A handwritten signature in cursive script, appearing to read "Don Wilbanks", is written over a horizontal line.

Don Wilbanks, President

408-B Interchange Street  
McKinney, TX 75071

Phone: 214-544-2121 Fax: 972-542-7097

TDLR License No. 18171

Regulated by The Texas Department of Licensing and Regulation  
P. O. Box 12157, Austin, Texas 78711, 1-800-803-9202, 512-463-6599  
website: [www.license.state.tx.us/complaints](http://www.license.state.tx.us/complaints)