



COLLIN COUNTY

Office of the Purchasing Agent  
2300 Bloomdale Road  
Suite 3160  
McKinney, Texas 75071  
www.collincountytx.gov

---

**ADDENDUM No. One (1)**

**Roof Replacement for Wells Building Farm Museum  
IFB #2014-172**

Effective: April 25, 2014

You are hereby directed to make changes to the Invitation For Bid in accordance with the attached information:

Add:

Pre-Bid Conference meeting attendees list  
Attachment A1-238T-Specifications for Alternate

Clarifications:

1. The base bid shows removing the existing metal panel roof and skylights and filling in the skylights with insulation and installing a new exposed fastener metal panel roof. The alternate bid requests a price for installing a new 238T standing seam panel roof. As part of the alternate price the existing metal panel shall be left in place and the void left shall be filled with an additional metal panel and install the new system.
2. The plan shows the metal framing to be attached to the foundation slab so that it will run vertically continuous next to the metal building framing. The metal framing shall be installed between the horizontal building framing so that the OSB covers any conduit against the horizontal framing but not the outlets and electric or phone installations on the framing.
3. The plans indicate 24 gauge framing is to be used while the specifications (07590) require 25 gauge framing. Specification (07590) should read 24 gauge framing.

Please note all other terms, conditions, specifications drawings, etc. remain unchanged.

Sincerely,  
Michalyn Rains, CPPO, CPPB  
Purchasing Agent