

Attachment D

Construction, Clean Agent Fire Protection System, McKinney Courthouse Data Center
IFB 2016-098

Answers/Clarifications to February 19, 2016 Site Walk Question

1. Does the local EPO switch on the Liebert PDU's have remote capabilities?

According to the original construction specifications section 16611, 2.19 Protection, the UPS systems were specified to have remote EPO capabilities. See Attachment E for additional record drawings.