

Attachment B

October 25, 2017 Pre-Bid Conference Questions and Answers

1. What sieve size is considered “fines”?

Answer: 3/8” crushed gravel w/ fines is further described as well-graded crushed gravel aggregate with particles no larger than 3/8” and 2-10% passing the #200 sieve.

2. Will alternate locations be provided for staging areas?

Answer: Staging areas are shown in the plans. Additional or alternate staging areas will be considered on a case-by-case basis and approved by the County and the YMCA.

3. Will the county consider other colors for the geocell system?

Answer: Gray or tan is shown in the specifications (Page 00801-2). The contractor may submit alternative colors for county approval.

4. What is the depth requirement for shaping/recompacting the subgrade?

Answer: Scarify and recompact the existing material a minimum of 6”

5. What is the time requirement for providing alternates?

Answer: Substitutions shall be submitted at least seven (7) consecutive calendar days prior to the date for receipt of bids (Page 0200-4). Substitution requests should be emailed to: jgriffin@co.collin.tx.us

6. Who is responsible for providing water?

Answer: The County will provide access to water via fire hydrants along the access roads within the camp.

7. Is there a time frame or schedule to complete the project?

Answer: The contractor will be responsible for submitting a construction schedule. No date to complete the project has been established.