



October 19, 2017

Roof Recovery
Collin County Justice Center
McKinney, Texas

ADDENDUM NUMBER THREE

The following questions were asked by bidding contractors. The responses required revision to the contract documents to add or clarify scope.

1. Q- The legend on Roof Plan sheets R1.1 through R1.6 indicates that the roofing control joint is detail 06/R1.8, but that detail is an HVAC support unit curb.

A- There are actually two details keyed in as 06 on R1.8. The detail on the left is the control joint detail and should have been labeled "08", and the legend on the plans should have been keyed to 08/R1.8. This slip joint detail is to be used to cover all roofing control joints even if there is not a building expansion joint under them. Please see attached revised drawings. Please note that the reference should change on the legend of all the Roof Plan sheets, but the control joint only occurs on R1.4 through R1.6 so only those sheets are attached to this Addendum.

Attachments:
Revised drawings R1.4, R1.5, R1.6 and R1.8

END OF ADDENDUM NUMBER THREE



Date of signing: 10/19/2017