

Rick Monk Facilities Director 4600 Community Avenue McKinney, Texas 75071 www.collincountytx.gov

Date:

March 15, 2024

To:

Commissioners Court

From:

Rick Monk/Facilities Director

RE:

FYI Change Order #1: 2022-292 Construction: Building Automation Upgrade,

Heat Transfer Solutions, Purchase Order 24001271

FYI for Purchase Order 24001271, change order #1 for modifying the sequence of operation to alternate chilled water pump leads on a weekly basis as recommended by Heat Transfer Solutions and supported by MD Engineering. The amount for change order # 1 is \$7,550 making the purchase order amount \$130,483.70.

RM/ke

Paid Mond 3/15/2024

OK B.M 7