

**Collin County Courthouse Parking Lot Gate Replacement  
IFB 2017-087**

**Pre-bid meeting Questions & Answers:**

**Question 1: Does the contractor or its employees need to have a background check or security clearance.**

*Answer: Refer to Special Condition (SC.03-12) on Page 120 of the Bid Document. Once the contract is awarded, a mandatory background check performed by Collin County shall be required for all personnel who will be onsite for this project. A County badge for access and identification shall be issued to all personnel and worn where visible at all times.*

**Question 2: What color does the gate operator need to be?**

*Answer: All gates shall be ordered from the manufacturer with white (RAL 9010) powder coat finish. Refer to Addendum No. 2, Section 00801 & 00802 Revised.*

**Question 3: What type of material shall the pavement be patched with?**

*Answer: Pavement patches or repairs beyond the limits shown in the plans shall be repaired with like material. Asphalt will be patched with asphalt; concrete will be patched with concrete. This item will not be paid for directly but subsidiary to Bid Item 800 – Install Barrier M30.*

**Question 4: Is testing and training included in the bid price?**

*Answer: The bid price for Bid Item 800 – Install Barrier M30 shall include the price for field quality control and testing as shown in Special Condition 3.04 Field Quality Control and 3.05 Continued Service and Documentation shown on Page 113 of the Bid Document.*