

IFB 2018-117, Construction, Collin County Adult Detention Center Generator After-Market Emissions Control

3/1/2018 Pre-Bid Meeting Clarifications

- 1.) Fuel Clarification- Note #5 E1.01- "... Maintain fuel in the generator(s) to support 8 hours of operation." The county will provide any fuel for the generator(s) after 8 hours.
- 2.) Temporary Generator Location Clarification- E5.01 shows the potential placement of temporary generator. Exact location will need to be field verified by the contractors prior to bid.
- 3.) Temporary Generator and Docking Station Installation Schedule Clarification- Install the temporary generator and docking stations at 7:00 AM.
- 4.) Temporary Generator and Docking Station Installation Clarification- In the event of an emergency power outage while installing the new docking station; install the temporary generator direct to the transfer switch to restore power immediately.