



Request Change Order #1(Revision 1)

To: Collin County/MD Engineering

Date March 16, 2022

Project: 2021-351 HVAC Replacement, Bldg. 900, Plano, Texas

Subject: Change Order #1

David, Next Gen Air request change order on below:

We found unit no FCU-50/CU-50, to have low static pressure, not delivery air flow/return air designed, upon further investigation found supply air only had a 12" and 8" discharge duct to area and on the return side a 14" flex return.

Too low for proper air delivery or return. Since new unit Carrier Model No. FV4CNB003L00, replaces a FV4CNB002, it's CFM is 875 CFM, above duct system cannot provide the proper ESP., We have recommended to the field to provide additional opening into supply and return. See Below:

Additional Materials, flex, grille and misc.	\$675.00
Labor at 6 hours x \$45.00	\$270.00
Sub-Total	\$945.00
Mark-Up at 10%	\$94.50
Original Contract	\$161,064.00
Change Order No. 1	\$1,039.50
Total Contract	\$162,103.50

Respectfully,
Next Gen Air

**MD Response-
MD Agrees with Next Gen Air recommendation.**

1. Provide dampers for supply and return to allow proper test and balance

Date:
MD Engineering 2022.03.17
07:46:47-05'00'



Texas Department of Licensing & Regulation P.O. Box 12157, Austin, Texas 78711
800-803-9205 or 512-463-6599 TACLA21752C
2109 Clear Lake Rd Ste 400 Weatherford, Texas 76087
817.420.7070 www.NextGenAC.com

Quote / Proposal / Estimate good for 30 days from date of bid.