

TEXAS COMMISSION ON JAIL STANDARDS

EXECUTIVE DIRECTOR
Brandon S. Wood



P.O. Box 12985
Austin, Texas 78711
Voice: (512) 463-5505
Fax: (512) 463-3185
<http://www.tcjs.state.tx.us>
info@tcjs.state.tx.us

August 4, 2022

The Honorable Chris Hill
Collin County Judge
2300 Bloomdale Rd., Suite 4192
McKinney, TX 75071


And

Sheriff Jim Skinner
Collin County Sheriff
4300 Community Ave.
McKinney, TX 75071

Dear Judge Hill and Sheriff Skinner,

Your request, in accordance with §511.0097, for the deletion of sprinkler heads in the inmate housing and holding cells of the planned Collin County Medical/Mental Addition was an approved item at the August 4, 2022 Commission Meeting. Please find enclosed the official action taken on your request. Please contact my office if you have any questions.

Respectfully,


Brandon S. Wood
Executive Director

cc: Charles Goodman, BSW Architects

Judge Bill Stoudt, Longview, Chair
Dr. Esmail Porsa, M.D., Houston, Vice-Chair
Ross Reyes, Melissa

Sheriff Kelly Rowe, Lubbock
Sheriff Raul "Pinky" Gonzales, Refugio
Patricia M. Anthony, Garland

Commissioner Ben Perry, Waco
Duane Lock, Southlake
Monica McBride, Alpine

*"The Commission on Jail Standards welcomes all suggestions and will promptly respond to all complaints directed against the agency or any facilities under its purview
To empower local government to provide safe, secure and suitable local jail facilities through proper rules and procedures while promoting innovative programs and ideas"*

COLLIN COUNTY

Request: Approve the Collin County Medical/Mental Addition to be designed without an automatic sprinkler system at **inmate housing**, all other areas of the facility will be provided with an approved automatic sprinkler system.

Commission Action:

Approved in accordance with §511.0097


August 4, 2022
Brandon S. Wood, Executive Director