

Fan Sumin (310) 256-6088
 5845 Shady Hill Circle
 Princeton, Texas 75407

Required:
 500 GPD Aerobic ATU
 500 GPD Dripfield
 5,000 s.f. coverage

Proposed:
 600 GPD Aerobic ATU
 750 Gallon Pump Tank
 5,040 s.f. coverage
 3 Zones @ 1680 s.f. each
 Each with 840 feet of line
 = 5,040 s.f. coverage

December 22, 2022

There is not a 100-Year Floodplain located on the property

All pipe running beneath driveways and sidewalks or up to surface improvements must be Schedule 80 pipe or sleeved in Schedule 40 pipe



County Road 441

Property Line

12/22/2022

David L. Watkins

North Scale:
 1" = 30'

