



## CHANGE ORDER RESPONSE

**DATE:** March 5, 2024

**PROJECT:** Collin County BAS Improvements

**TO:** Rick Monk, Collin County Director of Facilities

### RESPONSE:

MD Engineering concurs with the HTS BAS proposal (January 10, 2024) for \$7,550 with the following scope:

- Provide and install a new Distech BACnet MS/TP controller inside the Air-Cooled Chiller.
- Provide and install DDC controls and status for each chilled water pump (Quantity 2).
- Provide and install a temperature sensor for chilled water supply and return.
- Modify the sequence of operation to alternate chilled water pump leads on a weekly basis.

These items were not included in the original scope on the bid documents.

Sincerely,

**MD Engineering, LP, LLP**

Michael Smith, PE LEED® AP  
President

{Project Name}  
{RFI #} - Response  
{Date}  
Page 2 of 2