



# COLLIN COUNTY

Office of the Purchasing Agent  
2300 Bloomdale Road  
Suite 3160  
McKinney, Texas 75071  
www.collincountytx.gov

COLLIN COUNTY, TEXAS

ADDENDUM NO. ONE (1)

IFB NO. 2024-066

INVITATION FOR BID

FOR

CONSTRUCTION, ADULT DETENTION SMOKE-HEAT DETECTOR REPLACEMENT

DATE: MARCH 7, 2024

NOTICE TO ALL PROSPECTIVE BIDDERS:

PLEASE MAKE THE FOLLOWING CHANGES TO THE INVITATION FOR BID:

ADD PRE-BID MEETING ATTENDANCE LIST

PRE-BID QUESTION LIST WITH ANSWERS

ATTRIBUTE NO. 25: ADDENDUM NO. 1 ACKNOWLEDGEMENT

911 POTTER POINT LIST

2024-066 QUESTION LIST

TO SPECIFICATION BOOK - DIVISION 00 41 00 BID FORM - BID LINES PAGE 47

LINE 4 OPTIONAL ALTERNATE GRAND TOTAL - REWIRING THE FIRE ALARM INITIATING DEVICES WITH NEW PER FOOT QUANTITY: 1 UOM: FOOT ITEM NOTE: LINES 4.1 AND 4.2 MUST ADD UP TO THE OPTIONAL ALTERNATE GRAND TOTAL - REWIRING THE FIRE ALARM INITIATING DEVICES WITH NEW PER FOOT.

4.1 QTY: 1 UOM: FOOT DESCRIPTION: TOTAL MATERIAL COST TO REWIRE THE FIRE ALARM INITIATING DEVICES WITH NEW PER FOOT. CONTRACTOR SHALL PROVIDE ALL NECESSARY EQUIPMENT, APPROVED PATHWAYS, AND FACP PROGRAMMING. PLEASE INCLUDE ALL THESE COST INTO YOUR BID

4.2 QTY: 1 UOM: FOOT DESCRIPTION: TOTAL LABOR COST TO REWIRE THE FIRE ALARM INITIATING DEVICES WITH NEW PER FOOT. CONTRACTOR SHALL PROVIDE ALL NECESSARY EQUIPMENT, APPROVED PATHWAYS, AND FACP PROGRAMMING. PLEASE INCLUDE ALL THESE COST INTO YOUR BID

LINE 5 OPTIONAL ALTERNATE GRAND TOTAL - REPLACING ALL EXISTING EST 3 PANELS WITH EST 4 PANELS AND ASSOCIATED WORK. QUANTITY: 1 UOM: LUMP SUM ITEM NOTE: LINES 5.1 AND 5.2 MUST ADD UP TO THE OPTIONAL ALTERNATE GRAND TOTAL - REPLACING ALL EXISTING EST 3 PANELS WITH EST 4 PANELS AND ASSOCIATED WORK.

5.1 QTY: 1 UOM: LUMP SUM DESCRIPTION: TOTAL MATERIAL COST TO REPLACE ALL EXISTING EST 3 PANELS WITH EST 4 PANELS AND ASSOCIATED WORK. CONTRACTOR SHALL PROVIDE ALL NECESSARY EQUIPMENT, APPROVED PATHWAYS, AND FACP PROGRAMMING. PLEASE INCLUDE ALL THESE COST INTO YOUR BID

5.2 QTY: 1 UOM: LUMP SUM DESCRIPTION: TOTAL LABOR COST TO REPLACE ALL EXISTING EST 3 PANELS WITH EST 4 PANELS AND ASSOCIATED WORK. CONTRACTOR SHALL PROVIDE ALL NECESSARY EQUIPMENT, APPROVED PATHWAYS, AND FACP PROGRAMMING. PLEASE INCLUDE ALL THESE COST INTO YOUR BID

CHANGE FROM      BID CLOSE DATE 3/14/2024 2:00 PM  
                         TO      BID CLOSE DATE 3/21/2024 2:00 PM

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION AND SPECIFICATIONS REMAIN THE SAME.

SINCERELY,  
MICHELLE CHARNOSKI, NIGP-CPP, CPPB  
PURCHASING AGENT  
/RD

2  
5

**Addendum No. 1**

Please initial to verify your receipt of the addendum.

(Required: Maximum 1000 characters allowed)

**Bid Lines**

**1 Package Header**

Bid Grand Total.

Quantity:   1   UOM:   lump sum   Total: \$

Item Notes: Lines 1.1 and 1.2 must add up to the Bid Grand Total. Please provide bids on both Line 1 and Line 3.

Supplier Notes:

- No bid
- Alternate specification  
*(Attach separate sheet)*
- Additional notes  
*(Attach separate sheet)*

**Package Items**

**1.1** Total Material Cost for replacing approximately 450 smoke/heat detectors in the original Adult Detention Center (Clusters one and three, together with the main detention building from the Detention Lobby entrance to the loading dock area) and Sheriff's Office.  
*(Response required)*

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes:

- No bid
- Additional notes  
*(Attach separate sheet)*

**1.2** Total Labor Cost for replacing approximately 450 smoke/heat detectors in the original Adult Detention Center (Clusters one and three, together with the main detention building from the Detention Lobby entrance to the loading dock area) and Sheriff's Office.  
*(Response required)*

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes:

- No bid
- Additional notes  
*(Attach separate sheet)*

**2 Unit Prices**

*(Response required)*

Quantity:   1   Price: \$  Total: \$

Item Notes: Unit price shall include all materials, equipment, requirement and labor mentioned in the Specifications to provide and install one (1) replacement device.

Supplier Notes:

- No bid
- Alternate specification  
*(Attach separate sheet)*
- Additional notes  
*(Attach separate sheet)*

## Item Attributes

### 1. State Unit Price for: One (1) Siga-OSD device and installation of replacing existing device

Bidder shall provide a unit price for any additional One (1) Siga-OSD device that may be required during the project other than the estimated four hundred and fifty (450) smoke/heat detectors stated in the Specifications. Unit price shall include all materials, equipment, requirements stated in the Specifications and labor to provide and install one (1) replacement device.

(Required: Numbers only)

### 2. State Unit Price for: One (1) Siga-HRD device and installation of replacing existing device

Bidder shall provide a unit price for any additional One (1) Siga-HRD device that may be required during the project other than the estimated four hundred and fifty (450) smoke/heat detectors stated in the Specifications. Unit price shall include all materials, equipment, requirements stated in the Specifications and labor to provide and install one (1) replacement device.

(Required: Numbers only)

### 3. State Unit Price for: One (1) Siga-SD device and installation of replacing existing device

Bidder shall provide a unit price for any additional One (1) Siga-SD device that may be required during the project other than the estimated four hundred and fifty (450) smoke/heat detectors stated in the Specifications. Unit price shall include all materials, equipment, requirements stated in the Specifications and labor to provide and install one (1) replacement device.

(Required: Numbers only)

## 3 Package Header

Alternate Grand Total

Quantity:   1   UOM:   lump sum   Total: \$

Item Notes: Lines 3.1 and 3.2 must add up to the Alternate Grand Total. Please provide bids on both Line 1 and Line 3.

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Alternate specification  
(Attach separate sheet)
- Additional notes  
(Attach separate sheet)

## Package Items

**3.1** Total Material Cost to retrofit to provide electric supervision on fire sprinkler isolation and control valves in lieu of existing chains and padlock. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

(Response required)

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Additional notes  
(Attach separate sheet)

**3.2** Total Labor Cost to retrofit to provide electric supervision on fire sprinkler isolation and control valves in lieu of existing chains and padlock. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

*(Response required)*

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Additional notes  
*(Attach separate sheet)*

**4 Package Header** **ADDED IN ADDENDUM NO. 1**

Optional Alternate Grand Total - Rewiring the fire alarm initiating devices with new per foot.

Quantity:   1   UOM:   foot   Total: \$

Item Notes: Lines 4.1 and 4.2 must add up to the Optional Alternate Grand Total - Rewiring the fire alarm initiating devices with new per foot.

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Alternate specification  
*(Attach separate sheet)*
- Additional notes  
*(Attach separate sheet)*

**Package Items**

**4.1** Total Material Cost to rewire the fire alarm initiating devices with new **per foot**. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

*(Response required)*

Quantity:   1   UOM:   foot   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Additional notes  
*(Attach separate sheet)*

**4.2** Total Labor Cost to rewire the fire alarm initiating devices with new **per foot**. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

*(Response required)*

Quantity:   1   UOM:   foot   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Additional notes  
*(Attach separate sheet)*

**5 Package Header** **ADDED IN ADDENDUM NO. 1**

Optional Alternate Grand Total - Replacing all existing EST 3 panels with EST 4 panels and associated work.

Quantity:   1   UOM:   lump sum   Total: \$

Item Notes: Lines 5.1 and 5.2 must add up to the Optional Alternate Grand Total - Replacing all existing EST 3 panels with EST 4 panels and associated work.

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

- No bid
- Alternate specification  
*(Attach separate sheet)*
- Additional notes  
*(Attach separate sheet)*

## Package Items

**5.1** Total Material Cost to replace all existing EST 3 panels with EST 4 panels and associated work. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

*(Response required)*

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

No bid  
 Additional notes  
*(Attach separate sheet)*

**5.2** Total Labor Cost to replace all existing EST 3 panels with EST 4 panels and associated work. Contractor shall provide all necessary equipment, approved pathways, and FACP programming. Please include all these cost into your bid.

*(Response required)*

Quantity:   1   UOM:   lump sum   Price: \$  Total: \$

Supplier Notes: \_\_\_\_\_  
\_\_\_\_\_

No bid  
 Additional notes  
*(Attach separate sheet)*