

Construction & Projects 4600 Community Ave. McKinney, Texas 75071 Phone: 972-547-5340 FAX: 972-547-5385 www.collincountytx.gov

To:	Commissioners Court
From:	Sandeep Kathuria / Director of Building Projects
Date:	August 6, 2024
Subject:	Change Order to Sedalco Inc. for Central Utility Plant

PCO #13 – Existing conditions require the installation of adapters to complete the chilled water tie-ins to the existing system. The fusion weld per the contract documents cannot be completed because existing valves will not completely close. The proposed adapters allow for the tie-in to be complete while the flow of water continues.

Total for this change order \$58,456.70 or 0.023% of contract.

Total Change Orders for this Project - \$2,775,107.40 or 0.11% of contract.

Thank you.