



**MEMORANDUM**

**DATE:** February 6, 2025

**PROJECT:** 2024-403 Construction, Collin County Courthouse Fire Sprinkler Pipe Replacement

**TO:** Ruyue (Eleven) Ding

**RE:** Contractor Recommendation

Eleven,

We have reviewed the documentation provided and concur with the recommendation of awarding this project to Summit INC. The award is for Option 2 which includes all material and labor for replacing the existing dry pipe sprinkler system with new dry pipe sprinkler system and include a nitrogen generator to keep the system pressurized with nitrogen for Collin County Courthouse. Please let me know if you have any questions.

Sincerely,  
**MD Engineering, LLP**

Michael Smith, PE LEED® AP  
President