



ADDENDA 1- 3
IFB No. 2024-480
920 Juvenile Probation Renovation

Addenda Issued:

Addendum #1

Feb 3, 2025 4:45 PM

ADDED ATTACHMENT L: [L - 2024-480 Pre-Bid Meeting Attendance 2 Day](#) containing list of attendees of mandatory pre-bid site walks from both days

ADDED ATTACHMENT M: [M - CC 920 L1 Juvenile Probation - Field Engineering Strikethroughs](#) showing strikethrough of references to Field Engineering in Table of Contents and Project Management & Coordination section.

ADDED ATTACHMENT N: [N - Photos from 920 Building](#) containing photographs of existing finishes of the second floor bathrooms as well as photographs of the chase area showing second floor data/telco cables to be pulled down.

Addendum #2

Feb 13, 2025 12:20 PM

Revised Question and Product Substitution Submission Deadline from ~~February 13, 2025, 2:00pm~~ to **February 27, 2025, 2:00pm**

Revised Bid Opening from ~~March 6, 2025, 2:00pm~~ to **March 20, 2025, 2:00pm**

Revised response deadline in Section 004513 Vendor Submissions, Question No. 7 Bid Bond from ~~March 6, 2025, 2:00pm~~ to **March 20, 2025, 2:00pm**

Addendum #3

Feb 27, 2025 9:33 AM

Added attachments [O - FP1 - Collin County Juvenile Probation 2025-02-14](#) and [P - FP2 - Collin County Juvenile Probation 2025-02-14](#). These attachments contain the **revised FP1** and **FP2** drawings to **replace the original FP1 and FP2** drawings contained on pages 36 & 37 of attachment [J - CC 920 L1 Juvenile Probation Remodel - Project Drawings 12-10-2024](#).

The existing EST3 system is being made obsolete soon so we are upgrading the existing EST3 system with the new EST4 system. The existing devices on the 2nd floor should all be backwards compatible with the new system so they just need to be re-connected at the new panel. As shown on the drawings, some of the existing 1st floor devices will be reused, but all new devices called for will be EST4 models in lieu of EST3.